Certificate of Compliance

Certificate Number EX:

EX3933 / 2008-08-11

Report Reference April

April 26, 2000

Issue Date 2008 September 15



Issued to:

ANSUL INC.

1 Stanton St.

Marinette, WI 54143

This is to certify that representative samples of

Foam Liquid Concentrate:

Ansul Fluoroprotein 3 Percent (FP-1802), Nominal 3 percent Fluoroprotein

Foam

Have been investigated by Underwriters Laboratories Inc.® in accordance

with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Foam Equipment and Liquid Concentrates, UL 162.

Additional Information:

Foam is generally produced by the addition of a foam liquid concentrate to water and mechanically mixing air into the foam solution. Some foam solutions may be discharged through equipment that does not mix air into the solution as indicated in the individual Listings.

Foam is suitable for use on fires involving ordinary hydrocarbon petroleum products, but may not be suitable for use on fires involving polar solvent fuels. Concentrates investigated for use on polar solvent fuels are noted in the individual Listings.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:

with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:

Tracey Milton

Underwriters Laboratories Inc

Reviewed by

Donald Ross

Underwriters Laboratories Inc.

-Donal Ross